



T&S BRASS AND BRONZE WORKS, INC.  
 2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690  
 PHONE 800-476-4103 FAX 864- 834-3518



Model No.

B-CW-1/2

Item No.:


REG.#A2601  
ISO #9002

Job Name:

Architect/Engineer Approval:

Notes:

1/2" NPT FEMALE INLET  
GAGE FIT ± 1 TURN



1/2" NPT FEMALE OUTLET  
GAGE FIT ± 1 TURN

**NOTES:**

1. MAXIMUM PRESSURE 400 PSI AT 200° F
2. NOT TO BE USED FOR NATURAL GAS APPLICATIONS.

Product Description:

VERTICAL CHECK VALVE FOR WATER ONLY  
WITH 1/2" NPT INLET & OUTLET

Drawn:

WJS

Approved

CA

Checked

ARY

Scale:

1' = 1'

Date:

10/2/95